

## Er. T. R. Dutta

BE (Civil), MBA, FIV

- ◆ E RTP of Guwahati Metropolitan Development Authority & Guwahati Municipal Corporation
- ◆ Competent Person (Approved by Chief Inspector of Factories, Govt. of Assam)
- ◆ Govt. Approved Valuer ◆ Chartered Engineer

## T. R. DUTTA & ASSOCIATES

Consulting Civil Engineering Firm

House No.- 99, First Floor,  
Opposite bylane-12, Rajgarh Road, Guwahati-781007  
Ph. No. +91-98640-12902  
email tuwaramdutta@gmail.com  
GSTIN : 18AHIPD5997N1Z1

Ref.....

Date : 24-04-2024

### TO WHOM IT MAY CONCERN

1. Name of the School : **GODWINS SCHOOL**
2. Full Postal Address of the Factory : **GOROLIA, SARUSAJAI, P. O.-SAUKUCHI, GUWAHATI, PIN-781034**
3. Number of floors on which workers will be employed : **THREE**

*Certified that I have inspected the building on 09/04/2024 and examined the various parts with special reference to the emergency exit plan etc. I am of the opinion that the building is structurally sound that its stability will not be endangered by its use as a **SCHOOL BUILDING**.*



*T.R. DUTTA*  
BE (CIVIL) FIV  
Consulting Engineer  
24/04/2024

### **Er. TUWARAM DUTTA**

Registered Technical Person,  
GMDA

#### Office Address

M/s T. R. Dutta & Associates  
99, Rajgarh Road, Ghy - 7  
Ph. 98640-12902 (M)  
0361-2464840 (O)



### Certificate of Structural Stability

REF. NO. - EREC/GWS/2015-D-0004  
Date: 27/09/2015

Certified that the RCC School building under matter & title "GODWINS SCHOOL" situated at Gopinoli, Sonmagan, P.O., Soukateh Guwahati- 781034, Kamrup (M. Assam) is duly inspected by us (EREC Team) and carryout the NDT Test for issue the Technical Safety Certificate against Stability of RCC building as on date.

The test data recorded during testing and physical observations are thoroughly analyzed. And after analyzing & scrutinizing the whole data, the average compressive strength of the building is found  $>30 \text{ N/mm}^2$ . Scrutinizing the resultant strength, it can be revealed that the quality of concrete of the building may be considered under the category of Poor/Normal (Standard/Good) subject to Retrofitting/ Rehabilitation/ Repair in some portions.

Date: 27/09/15



This report is a technical one and shall be valid for technical concern only.

Corporate Office  
MPG Complex, R-2 Rupnagar, Guwahati - 781032  
Hello : 90850-68613, 98640-68613, 98640-32550  
E-mail : mppguw2@rediffmail.com, Website: www.erec.in

Lab wings : Erec India Research Laboratory

